

Comm Hill 2 Phase II Perimeter Sample Results

Week of September 30th through October 5th, 2019

Sampling Date	P1			P2			P3			P4			P5			P6		
	Chrysotile	Amphibole	Structures/cc	Chrysotile	Amphibole	Structures/cc	Chrysotile	Amphibole	Structures/cc	Chrysotile	Amphibole	Structures/cc	Chrysotile	Amphibole	Structures/cc	Chrysotile	Amphibole	Structures/cc
9/30/2019	2	ND	0.0020	3	ND	0.0030	3	ND	0.0029	16	ND	0.0165	10	ND	0.0099	ND	ND	<0.0010
10/1/2019	6	ND	0.0058	ND	ND	<0.0010	2	ND	0.0019	4	ND	0.0038	10	ND	0.0099	ND	ND	<0.0009
10/2/2019	4	ND	0.0038	ND	ND	<0.0010	8	2	0.0095	11	ND	0.0107	5	ND	0.0047	1	ND	0.0009
10/3/2019	2	1	0.0028	4	ND	0.0038	5	ND	0.0046	10	ND	0.0094	3	ND	0.0028	1	1	0.0019
10/4/2019	1	1	0.0020	4	ND	0.0040	7	ND	0.0067	19	1	0.0230	1	ND	0.0010	1	ND	0.0009
10/5/2019	2	ND	0.0018	ND	ND	<0.0009	4	ND	0.0037	ND	ND	<0.0010	1	ND	0.0009	1	ND	0.0010
BAAQMD Guidelines											<0.016 Structures/cc							

- 1 - Chrysotile Asbestos
- 2 - Amphibole Asbestos - Including regulated and non-regulated amphibole asbestos
- 3 - Structures/CC - Calculated Asbestos Structure Concentration per CC Air

ND

Indicates that no asbestos structures were detected in the grid openings scanned

BAAQMD Guidelines Trigger Level for increased dust control measures