Comm Hill 2 Phase II Perimeter Sample Results

Week of March 6th through March 10th, 2023

Sampling Date	P1			P2			P3			Р4			P5		
	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³
3/6/2023															
3/7/2023															
3/8/2023				3	ND	0.0030							ND	ND	<0.0010
3/9/2023															
3/10/2023															

BAAQMD Guidelines

<0.016 Structures/cc

Sampling	P6			Р7			P8			P9d			P10e		
Date	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³
3/6/2023															
3/7/2023															
3/8/2023	ND	ND	<0.0010												
3/9/2023															
3/10/2023															

BAAQMD Guidelines

<0.016 Structures/cc

- 1 Chrysotile Asbestos
- 2 Amphibole Asbestos Including regulated and non-regulated amphibole asbestos
- 3 Structures/CC Calculated Asbestos Structure Concentration per CC Air

ND Not Detect

BAAQMD Guidelines Trigger Level for increased dust control measures

NM Not Measured

1/20/2022 Sampling Location moved from P10d to P10e