

Comm Hill 2 Phase II Perimeter Sample Results
 Week of April 17th through April 21st, 2023

Sampling Date	P1			P2			P3			P4			P5		
	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³
4/17/2023															
4/18/2023				ND	ND	<0.0010							ND	ND	<0.0010
4/19/2023				ND	ND	<0.0010							ND	ND	<0.0010
4/20/2023				6	ND	0.0062							ND	ND	<0.0010
4/21/2023															
BAAQMD Guidelines <0.016 Structures/cc															

Sampling Date	P6			P7			P8			P9d			P10e		
	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³
4/17/2023															
4/18/2023	ND	ND	<0.0010	ND	ND	<0.0010	ND	ND	<0.0010	5	ND	0.0049	2	ND	0.0020
4/19/2023	ND	ND	<0.0010	ND	ND	<0.0010	1	ND	0.0010	7	ND	0.0072	3	ND	0.0031
4/20/2023	ND	ND	<0.0010	1	2	0.0031	5	ND	0.0051	4	ND	0.0041	11	ND	0.0113
4/21/2023															
BAAQMD Guidelines <0.016 Structures/cc															

1 - Chrysotile Asbestos

2 - Amphibole Asbestos - Including regulated and non-regulated amphibole asbestos

3 - Structures/CC - Calculated Asbestos Structure Concentration per CC Air

ND Not Detect

BAAQMD Guidelines Trigger Level for increased dust control measures

NM Not Measured

1/20/2022 Sampling Location moved from P10d to P10e