

Comm Hill 2 Phase II Perimeter Sample Results

Week of July 27th through July 31st, 2020

Sampling Date	P1			P2			P3			P4			P5		
	Chrysotile	Amphibole	Structures /cc	Chrysotile	Amphibole	Structures /cc	Chrysotile	Amphibole	Structures /cc	Chrysotile	Amphibole	Structures /cc	Chrysotile	Amphibole	Structures /cc
7/27/2020	1	ND	0.0010	2	ND	0.0019	ND	ND	<0.0010	5	ND	0.0049	20	ND	0.0240
7/28/2020	ND	1	0.0009	5	ND	0.0047	3	2	0.0047	5	ND	0.0048	1	ND	0.0009
7/29/2020	ND	ND	<0.0009	ND	ND	<0.0009	ND	ND	<0.0010	21	ND	0.0204	1	ND	0.0010
7/30/2020	ND	ND	<0.0009	ND	1	0.0010	ND	2	0.0019	2	ND	0.0019	6	ND	0.0057
7/31/2020	ND	ND	<0.0010	3	ND	0.0029	ND	ND	<0.0010	4	1	0.0049	ND	ND	<0.0010
BAAQMD Guidelines										<0.016 Structures/cc					

Sampling Date	P6			P7			P8		
	Chrysotile	Amphibole	Structures /cc	Chrysotile	Amphibole	Structures /cc ³	Chrysotile	Amphibole ²	Structures /cc ³
7/27/2020	20	ND	0.0245	1	ND	0.0010	8	ND	0.0077
7/28/2020	ND	ND	<0.0010	2	ND	0.0019	5	ND	0.0047
7/29/2020	1	ND	0.0010	2	ND	0.0019	2	ND	0.0019
7/30/2020	1	ND	0.0010	4	ND	0.0038	1	ND	0.0010
7/31/2020	ND	ND	<0.0010	ND	ND	<0.0010	8	ND	0.0077
BAAQMD Guidelines <0.016 Structures/cc									

1 - Chrysotile Asbestos

2 - Amphibole Asbestos - Including regulated and non-regulated amphibole asbestos

3 - Structures/CC - Calculated Asbestos Structure Concentration per CC Air

ND Indicates that no asbestos structures were detected in the grid openings scanned

BAAQMD Guidelines Trigger Level for increased dust control measures