

Comm Hill 2 Phase II Perimeter Sample Results
 Week of October 19th through October 23rd, 2020

Sampling Date	P1			P2			P3			P4			P5		
	Chrysotile	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³
10/19/2020	ND	ND	<0.0009	ND	1	0.0010	ND	ND	<0.0009	ND	ND	<0.0010	ND	ND	<0.0010
10/20/2020	ND	1	0.0009	1	ND	0.0009	ND	1	0.0009	4	1	0.0047	9	ND	0.0084
10/21/2020	8	1	0.0084	1	ND	0.0009	14	ND	0.0133	16	ND	0.0154	18	1	0.0180
10/22/2020	ND	ND	<0.0010	2	3	0.0048	6	1	0.0068	9	ND	0.0087	ND	ND	<0.0010
10/23/2020	2	ND	0.0019	ND	ND	<0.0010	1	ND	0.0010	1	ND	0.0010	ND	1	0.0010
BAAQMD Guidelines <0.016 Structures/cc															

Sampling Date	P6			P7			P8			P9c			P10c		
	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile	Amphibole	Structures/cc	Chrysotile ¹	Amphibole	Structures/cc	Chrysotile ¹	Amphibole	Structures/cc	Chrysotile	Amphibole	Structures/cc
10/19/2020	ND	2	0.0018	ND	ND	<0.0009	6	1	0.0071	10	ND	0.0101	2	1	0.0030
10/20/2020	6	ND	0.0056	5	ND	0.0048	12	ND	0.0112	22	ND	0.0519	20	1	0.0281
10/21/2020	7	ND	0.0068	ND	ND	<0.0010	6	1	0.0066	7	1	0.0065	8	ND	0.0076
10/22/2020	2	1	0.0029	1	ND	0.0010	5	ND	0.0048	19	1	0.0190	11	ND	0.0105
10/23/2020	1	ND	0.0010	1	ND	0.0010	7	ND	0.0067	5	ND	0.0050	5	ND	0.0048
BAAQMD Guidelines <0.016 Structures/cc															

1 - Chrysotile Asbestos

2 - Amphibole Asbestos - Including regulated and non-regulated amphibole asbestos

3 - Structures/CC - Calculated Asbestos Structure Concentration per CC Air

ND

BAAQMD Guidelines Trigger Level for increased dust control measures